




CONTENTS

- EARLY DEVELOPMENT 2007
- HYDROPOWER DEVELOPMENT BY 2015
- DEFINITE FUTURE SCENARIO 2020
- HYDROPOWER DEVELOPMENT IN THE PERIOD 2020 2040
- HYDROPOWER DEVELOPMENT SUB-SCENARIO 1 (HPS1)
- PRELIMINARY CONSIDERATIONS FOR SUB-SCENARIOS HPS2 AND HPS3 IN RELATION TO ISH 0306 OPTIONS
- OBSERVATIONS ON MODELLING OF RULE CURVES FOR OPERATION












Project name	Commissioning Year	Installed Power (MW)	Average annual generation (GWh)
Manwan	1995	1 670	8 133
Dachaoshan	2003	1 350	7 397
Total		3 020	15 530









Project name	Commissioning Year	Installed Power (MW)	Average annual generation (GWh)
Previous table	Until 2007	3 020	15 530
Jinghong	2009	1 750	7 748
Xiaowan	2010	4 200	18 646
Gongguoqiao	2012	900	4 197
Nuozhadu	2014	5 850	23 240
Miaowei	2014	1 400	6 000 1)
Total		17 120	69 361

1) Data Not Found but calculated assuming plant factor about 50%

Definite Future Scenario 2020 Hydropower development in LMB




Assumptions and Considerations:


MS Dams

- Xayabury commercial operation is scheduled for 2019 and Don Sahong for 2018
- No other MS Dams before 2020

Tributary projects

- · All projects scheduled to 2020 are included
- All Nam Ou projects (1 to 7) are included
- Projects with less than 10 MW not considered







Project name	Commissioning Year	Installed Power (MW)	Average annual generation (GWh)
Previous table	Until 2015	17 120	69 361
Wunonglong	2016 - 2020	1 750	7 748 1)
Lidi	2016 - 2020	4 200	18 646 1)
Huangdeng	2016 - 2020	900	4 197 1)
Dahuaqiao	2016 - 2020	5 850	23 240 1)
Total		21 350	93 761

1) Data Not Found but calculated assuming plant factor about 50%

Hydropower Development in the period 2020 - 2040 Hydropower development in LMB



Assumptions and Considerations


- · Both MS Dams and Tributary projects included
- Most ambitious plan as all identified projects were included
- Projects have reached different stages(MoU, FS, PDA, CA)

To note that:

- With further studies/optimisation MW / GWh figures may chage;
- Some projects may be delayed after 2040
- Some projects may be cancelled (costs or socio-economy)

www.mrcmekong.org

Projects with less than 10 MW not considered







Project name	Commissioning Year	Installed Power (MW)	Average annual generation (GWh)
Previous table	Until 2020	21 350	93 761
Ganlanba	2020 - 2040	195	850 1)
Gushui	2020 - 2040	1 900	8 300 1)
Tuoba	2020 - 2040	1 400	6 000 1)
Total		24 845	108 911

1) Data Not Found but calculated assuming plant factor about 50%

Hydropower Development Sub-scenario 1 (HPS1) Hydropower development in LMB



Assumptions and considerations

- HPS1 corresponds «5 Project Cascade incl. Pak Beng, Luang Prabang, Xayaburi, Pak Lay, Sanakham » and the tributary dams
- No joint operation, i.e. each dam designed and operated for maximized energy production
- «No joint operation»; energy losses because of sediment flushing, fish passages, navigation, water quality are not accounted for

www.mrcmekong.org

Hydropower Development Sub-scenario 1 (HPS1) Hydropower development in LMB



Main characteristics for MS Dams

Project name	Full Supply Level	Installed Power (MW)	Average annual generation (GWh)
Pak Beng	340	912	4 775
Luang Prabang	320	1 410	5 600
Xayaburi	275	1 285	7 400
Pak Lay	240	1 320	5 948
Sanakham	215	660	3 696
Pak Chom	192	1 079	5 318
Ban Koum	115	2 000	8 433
Phou Ngoy	97.5	800	2 751
Don Sahong	73	260	2 044
Stung Treng	52	900	5 096
Sambor	40	1 703	7 691
Projects with red ink are not expected to be developed before 2040			

Hydropower Development Sub-scenario 1 (HPS1) Hydropower development in LMB Reasons for possible delay beyond 2040



<u>Pak Chom;</u> a transboundary project shared by Thailand and Lao, resettlement of a large number of people, project development in early stage with small progress.

Ban Koum; a transboundary project shared by Thailand and Lao, environmental and social conflicts (fishery, resettlement), project development in early stage with small progress.

<u>Phou Ngoy:</u> solely within Lao, about same dam height as for Ban Koum but longer dam (1 300 m versus 800 m), capacity smaller than for Ban Koum because much lower rated head and installed power (800 MW versus 2 000 MW), energy smaller than for Ban Koum (2 751 GWh versus 8 433 GWh), FS has been going on for some years and is still not finalized, environmental and social conflicts.

<u>Stung Treng</u>: solely within Cambodia, requires a long dam for a limited head, inundation of about 212 km², the reservoir length about 50 km, environmental and social conflicts (fishery, resettlement), further development reckommended to be delayed by 10 years in 2010 (in report authorised by MRC "Will Baxter: Cambodia most exposed dam threats").

Sambor; solely within Cambodia, requires a long dam for a limited head, capacity 2 600 MW requires 18 km long dam with more than 600 km² inundated area, capacity 1 703 MW requires more than 2 km long dam with more than 60 km² inundated area, environmental and social conflicts (fishery, resettlement), further development reckommended to be delayed by 10 years in 2010 (in report authorised by MRC "Will Baxter: Cambodia most exposed dam threats").

www.mrcmekong.org

Hydropower Development Sub-scenario 1 (HPS1) Hydropower development in LMB General criteria for examination of tributary projects



The list of hydropower projects in Hydropower Development in the period 2020 – 2040 have been subject to an examination with regards to the following aspects a far as relevant data have been available:

- Transboundary projects
- High costs (above 8 US cent per kWh)
- Plant Factor less than 40%
- Social and environmental red flags
- Identified projects with MOU in Laos in the range of 10 -15 MW whereof estimated 50% will be realized
- The potential of unidentified projects, i.e. projects that will be identified and realized in the period 2016 – 2040
- Hydropower potential in Thailand's provinces in the Northeast
- (Chiang Rai, Chiang Mai and Phayao) of LMB
- Projects with installation < 10 MW being under the provincial
 - jurisdiction in Lao are not included

Hydropower Development Sub-scenario 1 (HPS1) Hydropower development in LMB Summary of assumptions

Criteria	Capacity (MW)	Energy (GWh)
Hydropower Development in the period 2020 - 2040	16 377	74 679
Less MS Dams Pak Chom, Ban Koum, Phou Ngoy, Stung Treng, Sambor	6 482	29 289
Less some projects with plant factor below 40%	269	727
Less 50% of small hydro < 15 MW with MoU	390	1 500
Plus potential of unidentified projects	390	1 500
Plus potential in Thailand's provinces in the Norteast	60	200
Total	9 686	44 863

www.mrcmekong.org

Preliminary considerations for HPP Thematic Sub-scenario HPS2



HPS2: Level of Development equal to HPS1 but with Joint Reservoir Operation and good coordination among all MS Dams and by taking into account operation for navigation lock, fish passages, sediment flushing as well as measures to maintain acceptable water quality during and after flushing. HPS2 corresponds to Option 1.3 "5 Project Cascade + Hydro Peaking" in the ISH 0306 Study.

In coordination with the ISH 0306 Study team the following aspects will be discussed in the Hydropower Thematic Assessment Report:

- Outage of energy production during sediment flushing
- Reservoir filling period after sediment flushing
- Periodical water flows for fish passages and associated loss of energy production
- Water abstractions for navigation and loss of energy

Evaluation of the effects of the above aspects will be based on interpretation of results from the model runs, when they are available.


Preliminary considerations for HPP Thematic Sub-scenario HPS3




HPS3: With some basin wide Joint Operation and good coordination among all MS Dams and most tributary dams to strengthen flood management and flood protection measures throughout the LMB as well as to maximize navigation potential.


In coordination with the thematic teams for "Flood protection and floodplain infrastructure" and "Navigation" the following aspects will be discussed in the Hydropower Thematic Assessment Report:

- Loss of energy production during reservoir drawdown because of measure taken by the authorities as a precaution to damp expected flood
- Loss of energy production because of water demands for navigation locks and navigation in reservoirs and river stretches




Observations on modelling of rule curves for operation LMB MS Dams, Case Xayaburi







The spilling occurs in the high flow months August and September and it would probably happen in this magnitude even for higher reservoir water levels in the preceding months. This is because the live storage of Xayaburi is so small that water volumes can only be stored for some few hours and not on a seasonal basis. It seems that the Lower Rule Curve should have been lifted in order to lift the reservoir level in the period January – June. By such model change the head would be increased and consequently the energy production. With such a limited reservoir when compared to the turbine discharge, the reservoir level in the period January – June can be lifted closer to FSL without risking spilling of water.











IQQM model - Nam Theun 2 inflow, outflow, turbine flow and spilling 1986 - 2000

The spilling occurs in the high flow months August, September and October and amounts to close to 16% of the inflow. This is a rather high figure, and it can partly be explained by the simulated reservoir levels which show that the reservoir is not fully utilized. As Nam Theun 2 is a storage plant that can store 42% of the average yearly inflow, one should expect that the reservoir would be fully drained in June – July almost all years. The reduction in pressure head for MOL is only 3.4% of the maximum head, and this fact points towards better utilization of the reservoir to reduce the spilling.







According to this figure there is no spilling. For the period January to July the reservoir water level is drawn down by 12 to 33 m, say in average 22 m, which represents about 10% headloss in relation to the max head of 210 m during the 6 months.

It seems that the Lower Rule Curve should have been lifted in order to lift the reservoir level in the period January - June. By such model change the utilized head would be increased and consequently energy production increased and spilling reduced.

www.mrcmekong.org

The RTWG is requested to:



- Take note of the progress
- Provide guidance and if possible agree on the proposed mainstream and tributary dams included in development scenarios 2007, 2020, and 2040
- Provide guidance and if possible agree on the proposed mainstream dams included in Sub-scenario 1 (HPS#1) which include dams in the cascade upstream of Vientiane and Don Sahong
- Provide guidance and if possible agree that subsscenarios HPS#2 and HPS#3 conceptually are based on alternative operations of the dams (i.e., joint

 - operations)



Thank You

